WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43632
Permit No.
Basin 4-61

NOTICE OF INTENT NO. 24287

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO NEVADA 89801

ADDRESS AT WELL LOCATION BARRICK GOLDSTRIKE MINE

2. LOCATION SW ¼ NW ¼ Sec. 30 T 36 X N/S R 50 E EUREKA County
PERMIT NO. M/O 441 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL CASING WAS SEALED AND NOT PULLED				
WELL CASING WAS NOT RIPPED DUE TO SLOTTS				
ALREADY IN CASING A CEMENT SLURRY OF				
16LB./GAL WAS DISPLACED THROUGH OUT THE				
ENTIRE WELL FROM 240 FEET TO SURFACE				

'94 FEB -1 A11:11 STATE

Date started DECEMBER 22, 1993, 19
Date completed DECEMBER 22, 1993, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 435 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
14	Inches	0	Feet	20	Feet
6-1/2	Inches	20	Feet	435	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	28	.375	0	20
1-1/4	2	SCH 40	0	180

Perforations:
Type perforation SLOTTED
Size perforation 1/8"
From 180 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 175 feet to 435 feet

9. WATER LEVEL
Static water level 170 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 West 1500 South (Contractor)
Salt Lake City Ut 84104
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1829
Signed [signature] (By driller performing actual drilling on site or contractor)
Date JANUARY 4, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627