WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 43685
Permit No.
Basin 230

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1355-9

1. OWNER US Ecology Inc
MAILING ADDRESS PO# 578
Beatty Nev. 89003

ADDRESS AT WELL LOCATION SAME

2. LOCATION ¼ NW ¼ Sec. 35 T. 13S N/S R. 47 E. Nye County
PERMIT NO. Under Waiver (Issued by Water Resources) | Parcel No. | WELL # 002 (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE Monitoring
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Loose Sand + Gravel		0	24	24
Sand + Gravel		24	90	66
Sand + Gravel w/Bed of Clay		90	330	240
Sand + Gravel		330	367	37
Gravel	367		371	4
Sandy Clay + Gravel		371	390	19

Bentonite Plug 354 To 349.5

RECEIVED FEB 13 1991 STATE ENGINEER'S OFFICE

Date started 12-2, 19 89
Date completed 10-10, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 16" inches 40 Total depth 390 feet
12" inches 180'
10" inches 390
Casing record Carbon Steel + Stainless Steel
Weight per foot ..... Thickness .250

Diameter	From	To	
6" inches	0 feet	314 feet	CS
6" inches	314 feet	354 feet	S.S.
6" inches	374 feet	379 feet	S.S.
inches	feet	feet	
inches	feet	feet	
inches	feet	feet	

Surface seal: Yes ☑ No ☐ Type Grout
Depth of seal 345.4 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 349.5 feet to 374 feet
Silica Sand

Perforations:
Type perforation Stainless Steel Screen
Size perforation .010
From 354 feet to 374 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 356 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 70 °F Quality FAIR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Cook Drilling Co (Contractor)
Address RT 15-13 x 543 Amargosa Val. Nev 89020 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 5376 A
Nevada contractor's driller's number issued by the Division of Water Resources 830
Nevada driller's license number issued by the Division of Water Resources, the on-site driller .....
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 10-10-90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (01-627)