

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1827

OWNER Doug Fisher T. S. HENAR ADDRESS AT WELL LOCATION Off NO. Grandcanyon Drive
 MAILING ADDRESS 6608 Burgundy Way 89107

2. LOCATION SE 1/4 NW 1/4 Sec. 30 T. 19 N/S R. 60 E CLARK County

PERMIT NO. 48438 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cement Gravel		0	275	275
Loose Rockes		275	300	25
Gippsion		300	307	7
Hard Lime Stone		307	367	60
Cement Gravel		367	530	163
Loose Gravel		530	550	20
Frist Water	375			
Main Water Strata	530			

RECEIVED
 NOV 8 1984
 Div. of Water Resources
 Project Office - Las Vegas, NV

8. WELL CONSTRUCTION

Diameter hole 12 1/4 inches Total depth 550 feet
 Casing record 8 & 5/8
 Weight per foot 11.6 Thickness 156

Diameter	From	To
<u>8 & 5/8</u> inches	<u>0</u> feet	<u>550</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet


 Surface seal: Yes No Type Cement
 Depth of seal 55 feet
 Gravel packed: Yes No
 Gravel packed from 550 feet to 55 feet
 Perforations:
 Type perforation Factory
 Size perforation 12 PER FT
 From 530 feet to 490 feet
 From feet to feet

9. WATER LEVEL

Static water level 364 feet below land surface
 Flow 90 G.P.M. 80 P.S.I.
 Water temperature 59 ° F. Quality GOOD

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name VEGAS DRILL CO. Contractor
 Address 5956 Calvert L.V. 89130 Contractor
 Nevada contractor's license number 015972
 Nevada contractor's drillers number 944
 Nevada driller's license number 944 Actual Driller
 Signed Bruce Robinson Contractor
 Date 11-6-84



7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

AIR **BAKER TEST**
 G.P.M. 90 Draw down 67 feet 12 hours
 G.P.M. Draw down feet hours
 G.P.M. Draw down feet hours