WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43729
Permit No.
Basin 4-57

NOTICE OF INTENT NO. 21222

1. OWNER Newmont Gold Co.
MAILING ADDRESS PO Box 669
Carlin Nevada 89822

ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SE ¼ Sec. 5 T. 32 N/S R. 52 E. Eureka County
PERMIT NO. M0-184-L (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☑ PVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Alluvium		0	20	2
Silt Stone	✓	20	30	280

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6½ Inches		20 Feet	300 Feet
12 Inches		0 Feet	20 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
7	19	7/16	0	20
1¼ PVC	1	SCH-80	0	300

Perforations:
Type perforation .020
Size perforation Factory Slot
From 280 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 270 feet to 300 feet

9. WATER LEVEL
Static water level No Test feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name O'Keefe Drilling (Contractor)
Address PO Box 3810 (Contractor)
Butte Mont 59702
Nevada contractor's license number issued by the State Contractor's Board 27434
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1700
Signed Kevin Bowen (By driller performing actual drilling on site or contractor)
Date Oct 7 1992

Date started Sept 29, 1992
Date completed Oct 1, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

'92 OCT 14 P2:06
STATE ENGINEERS OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627