WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43749
Permit No.
Basin 6-88

NOTICE OF INTENT NO. 23261

1. OWNER Osborne/Walker Homes
MAILING ADDRESS For John & Karen Enloe
1281 Terminal Way, Suite 107, Reno 89502

ADDRESS AT WELL LOCATION
5400 Brooksmeadow
Reno, Nevada 89511

2. LOCATION NE ¼ SW ¼ Sec. 2 T. 17 N/S R. 19 E. Washoe County

PERMIT NO. N/A (Issued by Water Resources) | 45-472-37 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil & Boulders		0	4	4
Gravel, Sand & Boulders		4	28	24
Yellow clay		28	32	4
Brown sandy clay		32	200	168

'93 NOV -4 A10:29
STATE ENGINEER'S OFFICE

Date started 10-6-93, 19
Date completed 10-7-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx.	100	190	2

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
9 7/8 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	-1	200

Perforations:
Type perforation Mill slot
Size perforation 1/8 X 3
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 100+
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 100 feet to 200 feet

9. WATER LEVEL
Static water level 73 feet below land surface
Artesian flow None G.P.M. None P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EMDLCO (Contractor)
Address P.O. Box 8056 (Contractor)
Reno, Nevada 89507

Nevada contractor's license number issued by the State Contractor's Board 32166

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418

Signed Bruce Milles (By driller performing actual drilling on site or contractor)
Date 10-29-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627