

Washoe Permit # 4885

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 43757
Permit No. _____
Basin. G-89

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24461

1. OWNER: Joel Sanders
MAILING ADDRESS: 795 York Way Sparks NV 89431
ADDRESS AT WELL LOCATION: 40 Middlefield Pl Washoe City Carson City NV 89704
2. LOCATION: S.W. 1/4, N.W. 1/4 Sec 24 T 17 N S R 19 E Washoe County
PERMIT NO.: 004885 Issued by Water Resources
Parcel No.: 50-220-53 Subdivision Name: _____

3. WORK PERFORMED: New Well Replace Recondition Deepen Abandon Other _____
4. PROPOSED USE: Domestic Municipal/Industrial Irrigation Monitor Test Stock
5. WELL TYPE: Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	4	4
Brown Sands		4	15	11
Coarse Sands		15	65	50
Gray Silty Clay		65	103	38
Green & DG Sands	XX	103	125	22

8. WELL CONSTRUCTION
Depth Drilled: 125 Feet
Depth Cased: 125 Feet
HOLE DIAMETER (BIT SIZE)
From 0 Feet To 125 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.5/8</u>	<u>13.14</u>	<u>.188</u>	<u>0</u>	<u>125</u>

Perforations:
Type perforation: Mill slot
Size perforation: 3/32
From 105 feet to 125 feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
Depth of Seal: 100'
Placement Method: Pumped Poured
Gravel Packed: Yes No
From 100 feet to 125 feet

9. WATER LEVEL
Static water level: 8' feet below land surface
Artesian flow: _____ G.P.M. 30+ P.S.I.
Water temperature: Cold °F Quality: Good

Date started: 10-19, 1993
Date completed: 10-20, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>	<u>40'</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name: A.H. Pump Co. Contractor
Address: 5551 Hwy 60 E. #3 Carson City NV 89702 Contractor
Nevada contractor's license number issued by the State Contractor's Board: 1985 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1905
Signed: Michael Black
By driller performing actual drilling on site or contractor
Date: 10-21-93