WHITE--DIVISION OF WATER RESOURCES
CANARY--CLIENT'S COPY
PINK--WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43728
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 25058

1. OWNER Michael Casey
MAILING ADDRESS 1600 Allen Road
Fallon, NV 89406

ADDRESS AT WELL LOCATION 3000 Nicole CIrcle
Fallon, NV 89406

2. LOCATION SE ¼ NE ¼ Sec. 6 T. 18 N/S R. 29 E. Churchill County

PERMIT NO. (Issued by Water Resources) 006-691-41 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	3
Brown CLay		3	12	9
Fine Brown Sand		12	15	3
Brown Sand		15	18	3
Brown Clay		18	20	2
Brown Sand		20	22	2
Brown CLay		22	25	3
Brown Sand	X	25	31	6

'93 NOV 22 P2:17
STATE ENGINEER'S OFFICE

Date started 11-4, 19 93
Date completed 11-4, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 31 Feet Depth Cased 31 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	31 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	26

Perforations:
Type perforation Well Screen Steel
Size perforation .020
From 26 feet to 31 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 25
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 25 feet to 31 feet

9. WATER LEVEL
Static water level 2' 1" feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265

Nevada contractor's license number issued by the State Contractor's Board 29064

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753

Signed [signature] (By driller performing actual drilling on site or contractor)

Date Nov. 15, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627