

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 215783  
 Permit No. 2101  
 Basin 2101  
 NOTICE OF INTENT NO. 19502

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Help-U-Sell Realty ADDRESS AT WELL LOCATION Soda Lakes Road  
 MAILING ADDRESS 710 W. Williams Fallon, Nev. 89406  
 LOCATION NE 1/4 NE 1/4 Sec. 29 T 19 N/S R. 28 E Churchill County  
 PERMIT NO. 54321 08-531-37 Sunset Mobile Home Park  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Coarse Sand		0	16	16
Sandy Clay		17	17	1
Clay		19	29	10
Sand		29	30	1
Clay		30	36	6
Sand		36	40	4
Clay		40	42	2
Coarse Sand		40	46	4
Clay		46	48	2
Sand		48	50	2
Brown Clay		50	56	6
Green & Black Clay		56	65	9
Black Clay		65	67	2
Green Sand		67	87	20
Coarse Brown Sand		87	96	9
Brown Clay		99	108	9
Tan Sand		108	118	10
Tan Clay		118	119	11
Sand		119	129	10
Coarse Sand & pea gravel		129	154	25
Tan Clay		154	155	1

8. WELL CONSTRUCTION  
 Depth Drilled 155 Feet Depth Cased 155 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 14 Inches To 0 Feet 155 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8-5/8	16.94	.188	0	155

Perforations:  
 Type perforation Mill-Cut  
 Size perforation 1/8"  
 From 135 feet to 155 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100ft.  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 155 feet

9. WATER LEVEL  
 Static water level 20 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, Nev. 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1696  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 1-9-91

Date started Dec 12, 1991  
 Date completed Dec 16, 1991

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	