WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43786
Permit No.
Basin B-101

NOTICE OF INTENT NO. 25047

1. OWNER Eric Robinson Construction
MAILING ADDRESS 3812 Boyer Road, Fallon, NV 89406
ADDRESS AT WELL LOCATION 4145 Alcorn Road, Fallon, NV 89406

2. LOCATION NE ¼ NW ¼ Sec. 33 T 19 N/S R 28 E CHurchill County
PERMIT NO. (Issued by Water Resources) 08-691-93 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[XX] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[XX] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [XX] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	2	2
Brown Clay		2	10	8
Brown Sand		10	25	15
Brown Clay		25	30	5
Green & Brown Sandy Clay		30	50	20
Black Sandy Clay		50	55	5
Gray Clay		55	58	3
Fine Gray Sandy Clay		58	60	2
Brown COarse Sand	X	60	75	15

'93 NOV -8 P1:46
STATE ENGINEER'S OFFICE

Date started October 29, 19 93
Date completed October 29, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 75 Feet Depth Cased 75 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	75 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	70

Perforations:
Type perforation Well Screen Steel
Size perforation .025
From 70 feet to 75 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [XX] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 75 feet

9. WATER LEVEL
Static water level 11 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, Inc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753
Signed Wayne Parsons (By driller performing actual drilling on site or contractor)
Date 11/1/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627