

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24314

1. OWNER WESTWINDS CONST. ADDRESS AT WELL LOCATION 187 CANDYDANCE
 MAILING ADDRESS GARDNERVILLE GENOA

2. LOCATION SE 1/4 SE 1/4 Sec. 9 T 13 N R 19 E DOUGLAS County
 PERMIT NO. 17-100-38 GENOA Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Aluvil w Sandy clay</u>		<u>0</u>	<u>60</u>	<u>60</u>
<u>Sandy clay</u>		<u>60</u>	<u>64</u>	<u>04</u>
<u>Aluvil w clay</u>		<u>64</u>	<u>88</u>	<u>24</u>
<u>Sandy clay</u>		<u>88</u>	<u>91</u>	<u>3</u>
<u>Aluvil w clay</u>		<u>91</u>	<u>140</u>	<u>49</u>
<u>Aluvil w Sandy clay</u>		<u>140</u>	<u>180</u>	<u>40</u>
<u>Aluvil w clay</u>		<u>180</u>	<u>192</u>	<u>12</u>
<u>Aluvil w Some Sandy clay X</u>		<u>192</u>	<u>212</u>	<u>20</u>
<u>Aluvil w S. clay</u>		<u>212</u>	<u>223</u>	<u>11</u>
<u>Aluvil w Some Sandy clay X</u>		<u>223</u>	<u>252</u>	<u>29</u>
<u>Aluvil w clay</u>		<u>252</u>	<u>255</u>	<u>3</u>

8. WELL CONSTRUCTION

Depth Drilled.....Feet Depth Cased.....Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>10 5/8</u> Inches	<u>0</u> Feet	<u>220</u> Feet	
<u>5 5/8</u> Inches	<u>220</u> Feet	<u>255</u> Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>220</u>
<u>5"</u>	<u>10</u>	<u>.188</u>	<u>215</u>	<u>255</u>

Perforations:

Type perforation Factory Slotted/T.C.

Size perforation 3 1/2

From 19.5 feet to 215 feet
 From T.C. 155 feet to 195 feet
 From 5" T.C. 215 feet to 235 feet
 From 5" Factory 235 feet to 255 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50'

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 50 feet to 220 feet

9. WATER LEVEL

Static water level 185 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLON, NV

Nevada contractor's license number 27673
 issued by the State Contractor's Board.

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535

Signed Jerald W. Phinney
 By driller performing actual drilling on site or contractor

Date 10-6-93

Date started 9-3 1993
 Date completed 10-6 1993

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>15*</u>	<u>—</u>	<u>5</u>