

OFFICE USE ONLY  
Log No. 43819  
Permit No. \_\_\_\_\_  
Basin 10-129

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23231

1. OWNER Jon Branica ADDRESS AT WELL LOCATION NONE  
MAILING ADDRESS P.O. Box 150005 East FLY AV 89315

2. LOCATION SW 1/4 SE 1/4 Sec 11 T 16 N/S R 63 E White Pine County  
PERMIT NO. NA 10-460-29 Subdivision Name None

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	
Sandy clay		2	15	
gravel	water	15	22	
clay		22	27	
gravel	water	27	32	
clay		32	42	
gravel	water	42	44	
clay		44	45	
gravel		45	46	
clay		46	56	
gravel	water	56	57	
clay		57	63	
gravel	water	63	64	
clay		64	76	
gravel		76	76.5	
clay		76.5	78	
gravel	water	78	80	
clay		80	89	
gravel	water	89	91	
clay		91	95	
gravel	water	95	97	
clay		97	102.5	
gravel	water	102.5	104.5	
clay		104.5	108	
gravel	water	108	110	
clay		110	120	

8. WELL CONSTRUCTION  
Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)  
From To  
10 Inches 0 Feet 52 Feet  
8 Inches 52 Feet 120 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>12.9</u>	<u>.188</u>	<u>-1</u>	<u>120</u>

Perforations:  
Type perforation MILL  
Size perforation 4 x 2.5 x 6 row

From 62 feet to 83 feet  
From 91 feet to 112 feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 52'  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
From 52 feet to 120 feet

9. WATER LEVEL  
Static water level 22 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started Sept 22 1993  
Date completed Oct 15 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>21'</u>	<u>1</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name NATHAN R. MAYNARD Contractor  
Address P.O. Box 176 Lund N.V. 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 0022869  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Nathan Maynard  
By driller performing actual drilling on site or contractor  
Date Oct 26-93