

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **12778**

1. OWNER Woody Peterson ADDRESS AT WELL LOCATION Crystal NV  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NW 1/4 S1E 1/4 Sec. 7 T. 17S N/S R. 52 E Nye County  
 PERMIT NO. 21-431-14 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND		0	11	11
Clay Gravel		11	29	18
Cemented Rock		29	47	18
Clay Gravel		47	58	11
Cemented Gravel	WB	58	73	15
Conglomerate rock	WB	73	86	13
Clay Gravel		86	118	32
Gravel	WB	118	125	7

8. WELL CONSTRUCTION  
 Depth Drilled 125 Feet Depth Cased 125.4 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 125  
12 1/4 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 1/2</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>125</u>

Perforations:  
 Type perforation Factor, Saw cut  
 Size perforation 1/8 x 3  
 From 105 feet to 125 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 125 feet

9. WATER LEVEL  
 Static water level 30 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address HCP 78 Box 50358 Contractor  
Palump NV 89042  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Dan  
 By driller performing actual drilling on site or contractor  
 Date 1-31-94

Date started 1-20, 1994  
 Date completed 1-24, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED  
 FEB 08 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

