

OFFICE USE ONLY  
 Log No. 43853  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 12639

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Gibert Fisher ADDRESS AT WELL LOCATION 1420 W. Hardy Ln.  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 SE 1/4 Sec 17 T 20-S N/S R 53 E Nye County  
 PERMIT NO. 36-322-16 Cal Vegas Ranchos  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  Air  Other \_\_\_\_\_  
 5. WELL TYPE  Cable  Rotary  RVC  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Grey clay/caliche		4	14	10
Brown clay		14	43	29
Brown clay/caliche		43	48	5
Brown clay	X	48	118	70
Brown clay/caliche	X	118	140	22

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	140

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/4 in. width 8 in. long  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

RECEIVED  
 FEB 28 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

9. WATER LEVEL  
 Static water level 47 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started February 3 1994  
 Date completed February 3 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name JIM PIKE WELL DRILLING Contractor  
 Address P.O. BOX 56 Contractor  
Pahrump, NV. 89041

Nevada contractor's license number 17563 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324

Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date February 11, 1994