

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 43860  
 Permit No. 1  
 Basin. 1  
 NOTICE OF INTENT NO. 118145

1. OWNER Provenza Family Trust ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 SW 1/4 Sec. 11 T. 21-S N/S R. 53 E. Nye County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_  
 Issued by Water Resources 2 Parcel No. \_\_\_\_\_  
Provenza Sub. in Thousandaire Estates. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
White Clay		4	32	28
Caliche		32	46	14
Brown Clay		46	68	22
Hard Lime		68	72	4
White Clay	x	72	94	22
Brown Clay	x	94	156	62
Hard Grey Clay		156	174	18
Brown Clay	x	174	180	6

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 Inches To 0 Feet 180 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	18lbs.	.188	0	180

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1 in width 8 in long  
 From 140 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 180 feet

RECEIVED  
 FEB 15 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started Feb 6 1994  
 Date completed Feb 8 1994

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	1/4

9. WATER LEVEL  
 Static water level 56 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg Contractor  
 Address HCR 77 BOX 36525 Contractor  
 Nevada contractor's license number 7484 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725  
 Signed Charles Nyberg  
 By driller performing actual drilling on site or contractor  
 Date 2-12-94