WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43909
Permit No.
Basin L1-61

NOTICE OF INTENT NO. 26419

1. OWNER BARRICK GOLDSTRIKE MINE
MAILING ADDRESS P.O. BOX 29
ELKO NEVADA 89801

ADDRESS AT WELL LOCATION
BARRICK GOLDSTRIKE MINE

2. LOCATION SW ¼ NW ¼ Sec. 30 T 36 X N/S R 50 E EUREKA County
PERMIT NO. 55416 (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WEATHERED DIORITE		0	80	80
GRAY CLAY & DIORITE		80	150	70
GREEN GRAY DIORITE	2GPM	150	340	190
GREEN GRAY D ORITE	10GPM	340	460	120
GREEN GRAY DIORITE	10 GPM	460	740	280
GREEN GRAY DIORITE	20GPM	740	820	80

Date started MARCH 5, 19 94
Date completed MARCH 8, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIRLIFT	2-3		

8. WELL CONSTRUCTION
Depth Drilled 820 Feet Depth Cased 820 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
18-1/2 Inches	0 Feet	18 Feet
8 Inches	18 Feet	820 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	55	3/8	0	18
4	18	SCH 80	0	197
4	18	SCH 80	257	387
4	18	SCH 80	797	820

Perforations:
Type perforation SLOT
Size perforation .125
From 197 feet to 257 feet
From 387 feet to 797 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 72 feet to 820 feet

9. WATER LEVEL
Static water level 561 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature 70 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name LANG EXPLORATORY DRILLING (Contractor)
Address 2286 WEST 1500 SOUTH (Contractor)
SALT LAKE CITY UT 84104

Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410

Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 14, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627