WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43959
Permit No.
Basin 6-84

NOTICE OF INTENT NO. 23393

1. OWNER DAVID LORING
MAILING ADDRESS P.O. Box 70244
Reno, NV 89510

ADDRESS AT WELL LOCATION 3950 LaMay Ln.
Reno, NV 89511

2. LOCATION SE ¼ SE ¼ Sec. 11 T 18N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 040-491-21 (Parcel No.) SW Reno (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Boulder, gravel, clay		1	6	5
Brown sandy clay		6	14	8
Boulder & gravel with some clay		14	36	22
Brown sandy clay		36	53	17
Soft zone (NO WATER)		53	61	8
Brown sandy clay some gravels		61	115	54
Brown volcanic rock		115	135	20
Fracture	X	135	136	1
Brown volcanic rock		136	185	49
Fracture	X	185	186	1
Brown volcanic rock		186	200	14

Date started 3-7-94, 19
Date completed 3-8-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	200 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	200

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 135 feet to 155 feet
From 175 feet to 195 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 135 feet below land surface
Artesian flow G.P.M. 18 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed Edward F. [signature] (By driller performing actual drilling on site or contractor)
Date March 12, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627