WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43962
Permit No.
Basin 8-87

NOTICE OF INTENT NO.

1. OWNER Summit Engineering
MAILING ADDRESS 5405 Mae Anne Avenue
Reno, Nevada 89502

ADDRESS AT WELL LOCATION: Corner of Sierra and Fourth Street
Reno, Nevada

2. LOCATION SE ¼ NE ¼ Sec. 11 T 19 N/S R 19 E Washoe County

PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	10	10
Large Cobbles & Gravel		10	30	20
Coarse Sand & Gravel		30	80	50
Sandy Clay w/gravel streaks		80	105	25
Coarse sand & gravels		105	140	35
Sandy clay w/layers of gravel		140	150	10
Coarse sands & Coarse gravels		150	300	150

'94 FEB 16 P2:46 STATE ENGINEER

Date started 02 - 02, 19 94
Date completed 02 - 07, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		2 Hours

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	300 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8"	16.94	.188	+1	120
8"	22.36	.250	120	300

Perforations:
Type perforation Mill Slot
Size perforation 1/8"
From feet to feet
From 120 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 300 feet

9. WATER LEVEL
Static water level 33' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sargent Irrigation Company (Contractor)
Address 9955 North Virginia Street (Contractor)
Reno, Nevada 89506

Nevada contractor's license number issued by the State Contractor's Board 0021246

Nevada driller's license number issued by the Division of Water Resources, the on-site driller

Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2/11/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627