

OFFICE USE ONLY
 Log No. 43970
 Permit No. _____
 Basin 6-89

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24175

1. OWNER Central Enterprises ADDRESS AT WELL LOCATION 4105 Drake Way
 MAILING ADDRESS 3995 River Haven New Washoe City
Kenno NV 89509 Carson City NV 89706
 2. LOCATION N 1/4 SW 1/4 Sec 32 T. 17 N. S. R. 20 E Washoe County
 PERMIT NO. 050-393-09 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Overburden</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>Brown Clays</u>		<u>6</u>	<u>23</u>	<u>17</u>
<u>Cobbles & Gravels</u>		<u>23</u>	<u>30</u>	<u>7</u>
<u>Sandy Brown Clays</u>		<u>30</u>	<u>70</u>	<u>40</u>
<u>Course DA Sands</u>		<u>70</u>	<u>138</u>	<u>68</u>
<u>Hard DA Granite</u>		<u>138</u>	<u>174</u>	<u>36</u>
<u>Soft Sandy Clays</u>		<u>174</u>	<u>198</u>	<u>24</u>
<u>Broke DA Sands w/ small Gravels</u>	<u>XXX</u>	<u>198</u>	<u>225</u>	<u>27</u>

8. WELL CONSTRUCTION
 Depth Drilled 225 Feet Depth Cased 225 Feet
 HOLE DIAMETER (BIT SIZE)
 From 1 1/4 Inches To 0 Feet 225 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>225</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3/8 X 3/32
 From 200 feet to 225 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 55
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 55 feet to 225 feet

9. WATER LEVEL
 Static water level 160 feet below land surface
 Artesian flow _____ G.P.M. 15 P.S.I.
 Water temperature Cold °F Quality Good

Date started 3-3, 1994
 Date completed 3-4, 1994

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>	<u>35</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP CO.
5551 Hwy. 50 East #3
Carson City, Nevada 89705
 Address _____
 Nevada contractor's license number 31839
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael A. Haek
 By driller performing actual drilling on site or contractor
 Date 3-7-94