

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25072

1. OWNER Michael Grant ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 6300 Fair Haven Place 1899 Rice Road  
Reno, NV 89523 Fallon, NV 89406  
 2. LOCATION NW 1/4 SW 1/4 Sec. 24 T. 19 N. R 28 E. Churchill County  
 PERMIT NO. 08-293-17 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sand		0	13	13
Brown Clay		13	23	10
Brown Sand		23	32	9
Green Clay		32	35	3
Green Sand		35	48	13
Black Sand		48	51	3
Black Clay		51	53	2
Gray Clay		53	56	3
Gray Sand		56	74	18
Gray Clay		74	79	5
Gray Sand		79	87	8
Brown Clay		87	89	2
Brown Coarse Sand	XX	89	100	11

94 1000 -2 ARTESIAN STATE CONTRACTOR

8. WELL CONSTRUCTION  
 Depth Drilled 100 Feet Depth Cased 100 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 100 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	95

Perforations:  
 Type perforation Well Screen  
 Size perforation .035  
 From 95 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 100 feet

9. WATER LEVEL  
 Static water level 10' 6" feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Parsons Drilling, Inc. Contractor  
 Address P.O. Box 1265 Contractor  
Fallon, NV 89407-1265  
 Nevada contractor's license number issued by the State Contractor's Board 29064  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1753  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 2/23/94

Date started 2/3, 1994  
 Date completed 2/4, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

