

OFFICE USE ONLY  
 Log No. 44010  
 Permit No. \_\_\_\_\_  
 Basin 8-102

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22923

1. OWNER John + Donna Boelle ADDRESS AT WELL LOCATION 2350  
 MAILING ADDRESS 2350 Antelope St. Cantelope at Silver Springs  
Silver Springs NV 89429 NV 89428  
 2. LOCATION SE 1/4 NW 1/4 Sec. 20 T 17 N/S R. 25 E 6 1/2 N County \_\_\_\_\_  
 PERMIT NO. N/A 17-462-03 Clayton Sub. 1  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RYC  
 Air  Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	18	18
Sand gravel		18	32	14
Gravel, clay		32	61	29
clay		61	72	11
clay, gravel		72	90	18
gravel cemented		90	104	14
Clay Sand		104	115	11
Clay Gravel		115	158	43
Clay Sand		158	165	7
Clay Gravel	175	165	175	10
Course Sand, Gravel	200	175	200	25

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 201 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>1.38</u>	<u>1</u>	<u>200</u>

Perforations:  
 Type perforation Mill Perf  
 Size perforation 3/16 x 3 x 6 round Perf  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 20  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 33 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature C °F Quality Good

Date started 2/28/94, 19\_\_\_\_  
 Date completed 3/7/94, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>gpm 150</u>	<u>7</u>	<u>30 mins</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Peak Drilling Inc Contractor  
 Address PO 599 Contractor  
S.S. NV 89429  
 Nevada contractor's license number issued by the State Contractor's Board 6031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 2/23/94