WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44019
Permit No.
Basin 03-103

NOTICE OF INTENT NO. 26727

1. OWNER Steve Knight
MAILING ADDRESS 8165 Sutro Springs Rd.
Dayton, NV.

ADDRESS AT WELL LOCATION 8165 Mark Twain Estates
Dayton, Nevada

2. LOCATION NW ¼ SW ¼ Sec. 20 T. 17 N/S R. 22 E. Storey County
PERMIT NO. N/A (Issued by Water Resources) 03-294-04 (Parcel No.) Mark Twain Estates (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders and Gravels		0	83	83
Black Shale		83	164	81
Black Shale with Some counts		164	280	116
Black Shale with Fracures		280	360	80

STATE ENGINEERS OFFICE '94 FEB 15 A11:41

Date started 1-17, 1994
Date completed 1-19, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For 1½ Produced About 30 Gallons A min.		

8. WELL CONSTRUCTION
Depth Drilled 380 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	60 Feet
8 3/4 Inches		60 Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	13.00	+1	380

Perforations:
Type perforation Factory Cut
Size perforation 1-1/4 - 3 Rows
From 340 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-60
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 380 feet

9. WATER LEVEL
Static water level 240 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address Po Box 54 Silver Springs NV 89429 (Contractor's)
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1922
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 1-28-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627