WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44023
Permit No.
Basin 103

NOTICE OF INTENT NO. 24844

1. OWNER Steve Martin
MAILING ADDRESS 1591 Quail Dr.
Fairfield Calif.

ADDRESS AT WELL LOCATION 317 Martin St.
Dayton Nev.

2. LOCATION ~~SE~~ ¼ NW ¼ Sec. 30 T. 17 N/S R. 22 E. Storey County
PERMIT NO. NE (Issued by Water Resources) | 003-261-08 (Parcel No.) | Mark Twain Estates (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil & Cobble		0	2	2
Cemented gravel		2	250	248
Fractured Rock	—	250	350	100
Hard Rock		350	505	155
Grouted		350	505	
N39.313604				
W119.556334 NAD27				
Deepened under NDW 61958				

Date started 1-31, 19 94
Date completed 2-8, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
4	N/A	2 Hrs

8. WELL CONSTRUCTION
Depth Drilled 505 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	350 Feet
6 1/8 Inches	350 Feet	505 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188		350

Perforations:
Type perforation Factory Mill & Touch
Size perforation 3/32
From 250 feet to 350 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 350 feet

9. WATER LEVEL
Static water level 250 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eslo Drilling Co. (Contractor)
Address P.O. Box 1345 Dayton Nev. (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 47332A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller ~~[illegible]~~ 1757
Signed Troy Eslo (By driller performing actual drilling on site or contractor)
Date 2/8/94

JAN 23 '95 12:18 STATE ENGINEER'S OFFICE

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627