WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44024
Permit No.
Basin 8-103

NOTICE OF INTENT NO. 26731

1. OWNER Jerry Dressler
MAILING ADDRESS P.O. Box 603
Dayton, Nevada 89403

ADDRESS AT WELL LOCATION 382 Prospector
Dayton, NV. 89403

2. LOCATION SE ¼ NW ¼ Sec. 30 T. 17 N/S R. 22 E. Storey County

PERMIT NO. N/A (Issued by Water Resources) | 03-263-02 (Parcel No.) | Mark Twain (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravels And Boulders	0	0	43	43
Anda site		43	223	180
Anda site with some corts and Pirite		223	260	37
Andasite Soft		260	310	50
Hard Andasite		310	323	13
Andasite with some pirite		323	340	17
Gray clay		340	361	21
Fracured and Broken Andasite	✓	361	400	39

'94 FEB 15 A11:41
STATE ENGINEERS OFFICE

Date started 1-20 1994
Date completed 2-9 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For 2 Hours And produced about 100+ Gall a min.			

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 401 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	80 Feet
8 3/4 Inches	80 Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	400

Perforations:
Type perforation Factory cut
Size perforation 1X 1/4X 5 Rows
From 320 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 80
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 80 feet to 400 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address P.O. Box 599 Silver Springs (Contractor)
NV 89429
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] By driller performing actual drilling on site or contractor
Date 2-15-94

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY