

OFFICE USE ONLY
 Log No. 44028
 Permit No. I
 Basin 8-105
 NOTICE OF INTENT NO. 24584

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER WESTWINDS CONSTRUCTION ADDRESS AT WELL LOCATION 227 MY PEACH CT
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NW 1/4 SW 1/4 Sec 3 T 12 N R 19 E DOUGLAS County
 PERMIT NO. 19-042-19 Parcel No. FOOTHILL RD Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>DG 1/2 sandy clay</u>		<u>0</u>	<u>12</u>	<u>12</u>
<u>DG</u>		<u>12</u>	<u>44</u>	<u>32</u>
<u>DG 1/2 sandy clay</u>		<u>44</u>	<u>58</u>	<u>14</u>
<u>DG</u>	<u>x</u>	<u>58</u>	<u>105</u>	<u>47</u>
<u>DG 1/2 sandy clay</u>	<u>x</u>	<u>105</u>	<u>120</u>	<u>15</u>
<u>DG</u>	<u>N/A</u>	<u>120</u>	<u>160</u>	<u>40</u>

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation Factory Slotted
 Size perforation 3 x 3/32
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 100 feet to 160 feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Jerald W. Plummer
 By driller performing actual drilling on site or contractor
 Date 2-18-94

Date started 2-14, 1994
 Date completed 2-16, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25*</u>		<u>1</u>

'94 MAR 16 A9 58
 STATE ENGINEERS OFFICE