

OFFICE USE ONLY
 Log No. 44029
 Permit No.
 Basin 08-105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24574

1. OWNER MOLINE BUILDERS ADDRESS AT WELL LOCATION 903 RABBIT BRUSH
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE

2. LOCATION NW 1/4 NE 1/4 Sec 1 T 12 N R 20 E DOUGLAS County
 PERMIT NO. 23-480-50 WILDFLOWER Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	17	17
CEMENTED GRAVEL		17	58	41
SANDY CLAY w/GRAVEL		58	92	34
CLAY		92	113	21
SANDY CLAY w/GRAVEL		113	148	35
CEMENTED GRAVEL		148	182	34
SANDY CLAY w/GRAVEL		182	195	13
CEMENTED GRAVEL		195	218	23
SANDY CLAY w/GRAVEL		218	232	14
CLAY		232	245	13
SANDY CLAY w/GRAVEL		245	267	22
CLAY		267	286	19
SANDY CLAY		286	292	6
CLAY		292	327	35
COARSE SAND	✓	327	353	26
CLAY		353	-	-

'94 FEB 16 AM 0:31
 REVISITED
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 353 Feet Depth Cased 353 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 353
10 5/8 Inches 0 Feet 353 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>353</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 320 feet to 353 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 353 feet

9. WATER LEVEL
 Static water level 185 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Paul J. Mooney
 By driller performing actual drilling on site or contractor
 Date 1-21-94

Date started 1-11, 1994
 Date completed 1-21, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>20+</u>	<u>-</u>	<u>4</u>