



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24843

1. OWNER Darr Const ADDRESS AT WELL LOCATION 844 Regalia Ct. Gardnerville  
 MAILING ADDRESS P.O. Box 1008 Gardnerville  
 2. LOCATION SE 1/4 SW 1/4 Sec 13 T. 12 N/S R. 20 E. Douglas County  
 PERMIT NO. 29-441-27 Rhuenstrath Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Tan clay		0	45	45
Cobble + clay streaks + fine gravel		45	250	210
	180			
	215			
	230			
	240			

'94 MAR 18 AID:17  
 STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 250 Feet Depth Cased 250 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 250 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188</u>	<u>71</u>	<u>250</u>

Perforations:  
 Type perforation Factory Milled  
 Size perforation 3/32  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 210 feet to 250 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 250 feet

9. WATER LEVEL  
 Static water level 150 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature Cold °F Quality Clear

Date started Mar 9 1994  
 Date completed Mar 10 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Enloe Drilling Contractor  
 Address P.O. Box 1345 Dayton, Nev. Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 4739A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1450  
 Signed Lee A. Enloe  
 By driller performing actual drilling on site or contractor  
 Date Mar 10 1994