

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 44036
 Permit No. _____
 Basin 8-105

NOTICE OF INTENT NO. 24593

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER MR. JOHN BLISS ADDRESS AT WELL LOCATION 718 PINTO GARDNERVILLE
 MAILING ADDRESS P.O. BOX 63 WILLIAMSBURG, N.M.

2. LOCATION SW 1/4 NW 1/4 Sec. 24 T. 12 N. R. 20 E. DOUGLAS County
 PERMIT NO. 29-490-18 Parcel No. _____ Subdivision Name RHUNSTROTH
 Issued by Water Resources _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------------|--------------|------|-----|------------|
| Top Soil | | 0 | 3 | 3 |
| Cemented cobbles & gravel | | 3 | 8 | 5 |
| Sandy clay | | 8 | 14 | 6 |
| Cemented gravel | | 14 | 45 | 31 |
| Sandy Clay w/ some gravel | | 45 | 58 | 13 |
| Cemented gravel | | 58 | 65 | 7 |
| gravel w/ sandy clay | | 65 | 74 | 9 |
| Cemented gravel | | 74 | 88 | 14 |
| gravel w/ sandy clay | | 88 | 99 | 11 |
| Cemented gravel | ✓ | 99 | 109 | 10 |
| gravel w/ sandy clay | | 109 | 110 | 1 |
| Cemented gravel | ✓ | 110 | 115 | 5 |

8. WELL CONSTRUCTION
 Depth Drilled 115 Feet Depth Cased 115 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 115 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 3/8</u> | <u>12</u> | <u>1.88</u> | <u>0</u> | <u>115</u> |

Perforations:
 Type perforation Factory Slotted
 Size perforation 3 x 3/32
 From 95 feet to 115 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 115 feet

9. WATER LEVEL
 Static water level 73 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 66.6 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD, FALLON, NV 89406 Contractor

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535

Signed Jerald W. Rhinall By driller performing actual drilling on site or contractor
 Date 3-7-94

Date started 3-3 1994
 Date completed 3-7 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|------------|------------|-------------------------------|--------------|
| <u>Air</u> | <u>12+</u> | <u>—</u> | <u>1.5</u> |