

OFFICE USE ONLY
 Log No. 44037
 Permit No. 8-105
 Basin 8-105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23635

1. OWNER ELAINE STANG ADDRESS AT WELL LOCATION 637 Clydesdale
 MAILING ADDRESS 637 Clydesdale
GARDNERVILLE NV. 89410
 2. LOCATION NE 1/4 SW 1/4 Sec. 24 T 12 N R 20 E Douglas County
 PERMIT NO. 29-510-19 Parcel No. Ruberstroth Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown clay</u>		<u>0</u>	<u>18</u>	<u>18</u>
<u>cobbles gravel & boulders with red erial clay</u>		<u>18</u>	<u>72</u>	<u>54</u>
<u>cobbles gravel & boulders with red erial clay</u>		<u>72</u>	<u>145</u>	<u>73</u>

'94 MAR 17 P 4:23
 STATE ENGINEERS DEPT

8. WELL CONSTRUCTION
 Depth Drilled 145 Feet Depth Cased 145 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 Inches To 0 Feet
 From 8 Inches To 50 Feet
 From 50 Inches To 145 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>		<u>.188</u>	<u>0</u>	<u>145</u>

Perforations:
 Type perforation mill cuts
 Size perforation 1/8" x 2 1/2"
 From 120 feet to 140 feet
 From 120 feet to 140 feet
 From 120 feet to 140 feet
 From 120 feet to 140 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

9. WATER LEVEL
 Static water level 72 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality UNKNOWN

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DASIS DRILLING INC. Contractor
 Address P.O. Box 21421 CL. NV. 89421 Contractor

Date started 1-28-94
 Date completed 2-28-94

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>20</u>	<u>0</u>	<u>2</u>

Nevada contractor's license number issued by the State Contractor's Board 0023129
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1386
 Signed T. Angel
 By driller performing actual drilling on site or contractor
 Date 3-2-94