

OFFICE USE ONLY
 Log No. 7038
 Permit No. 8105
 Basin 8105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24591

1. OWNER PETE MCHALE ADDRESS AT WELL LOCATION 1820 CAMAS CT GARDNERVILLE
 MAILING ADDRESS MINDEN, NV

2. LOCATION SW 1/4 SW 1/4 Sec. 36 T. 13 N. R. 20 E DOUGLAS County
 PERMIT NO. 23-473-28 Parcel No. WILDFLOWER Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/GRAVEL		0	6	6
CEMENTED GRAVEL		6	12	6
SANDY CLAY w/GRAVEL		12	56	44
CLAY		56	68	12
SANDY CLAY w/GRAVEL		68	89	21
CLAY		89	96	7
SANDY CLAY		96	175	79
SANDY CLAY w/GRAVEL		175	219	44
CEMENTED GRAVEL	✓	219	240	21

94 MIN 16 AD
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 240 Feet Depth Cased 240 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 240 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>240</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 220 feet to 240 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 240 feet

9. WATER LEVEL
 Static water level 110 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 2-23 1994
 Date completed 2-26 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>20+</u>	<u>-</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. FALLON, NV 89406 Contractor
 Nevada contractor's license number 27673 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Pat A. M... By driller performing actual drilling on site or contractor
 Date 2-26-94