

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24587

1. OWNER GUS PAPPAS ADDRESS AT WELL LOCATION 1767 BITTERBRUSH GARDNERVILLE
 MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION SW 1/4 SW 1/4 Sec. 36 T. 13 N. R. 20 E DOUGLAS County
 PERMIT NO. 23-473-51 Parcel No. WILDFLOWER Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other
 4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC Air Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	6	6
CEMENTED GRAVEL		6	16	10
SANDY CLAY w/GRAVEL		16	23	7
CEMENTED GRAVEL		23	41	18
SANDY CLAY w/GRAVEL		41	116	75
SANDY CLAY		116	151	35
CEMENTED GRAVEL		151	159	8
SANDY CLAY w/GRAVEL		159	172	13
CEMENTED GRAVEL		172	193	21
SANDY CLAY w/GRAVEL		193	198	5
SAND + GRAVEL	✓	198	202	4
CEMENTED GRAVEL	✓	202	218	16
SANDY CLAY w/GRAVEL		218	220	2

B4 MAR 16 1994 STATE OF NEVADA

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>13</u>	<u>1.188</u>	<u>0</u>	<u>220</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 200 feet to 220 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 220 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. FALLON NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Pat J. Moore
 By driller performing actual drilling on site or contractor
 Date 2-22-94

Date started 2-15, 1994
 Date completed 2-22, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>8</u>