

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24578

1. OWNER JEIZRY PALMEIZ ADDRESS AT WELL LOCATION 2767 ESAW
 MAILING ADDRESS GARDNEVILLE, NV GARDNEVILLE

2. LOCATION NE 1/4 SW 1/4 Sec 35 T. 14 N. R. 20 E DOUGLAS County
 PERMIT NO. 21-250-58 JOHNSON LANE Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0	15	15
Sandy clay w/brublers		15	19	4
Sandy clay some gravel		19	30	
Sandy clay w/gravel		30	65	
sandy clay		65	92	
Sandy clay w/gravel		92	118	
Brn. Sandy clay		118	148	
Grey Sandy clay		148	190	
Grey Sandy clay w/course sand		190	225	
Grey Sandy clay		225	270	
Grey Sandy clay w/course sand	X	270	285	
Grey Sandy clay w/course sand & gravel	X	285	303	
Grey Sandy clay		303	305	

8. WELL CONSTRUCTION
 Depth Drilled 305 Feet Depth Cased 305 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 305 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>305</u>

Perforations:
 Type perforation Factory Slotted
 Size perforation 3X 3/32
 From 285 feet to 305 feet
 From T.C. 270 feet to 285 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 305 feet

9. WATER LEVEL
 Static water level 130 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality good

Date started 1-25, 1994
 Date completed 2-2, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>30+</u>		<u>1.5</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. Contractor
FALLON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Jerald W. Phinney
 By driller performing actual drilling on site or contractor
 Date 2-2-94