

OFFICE USE ONLY  
Log No. 44045  
Permit No. 9-107  
Basin 9-107

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 25462

1. OWNER RENE CARDINAL ADDRESS AT WELL LOCATION 735 DAY LN  
MAILING ADDRESS 90 PINON DR WELLINGTON NV 89444  
2. LOCATION NW 1/4 NE 1/4 Sec 9 T.11 N/S R.23 E. Lyon County  
PERMIT NO. 1023106 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - DG		0		20
DG		20		40
DG		40		60
DG		60		80
DG Boulders		80		100
Granite Boulders		100		120
DG Boulders		120		140
DG Boulders		140		160
DG Boulders		160		180
HARD ROCK DG		180		200
HARD ROCK DG		200		220
HARD ROCK DG		220		240
DG Boulders		240		260
DG Boulders		260		280
DG Boulders		280		300

8. WELL CONSTRUCTION  
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)  
From 12 1/4 Inches To 0 Feet 300 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8"</u>		<u>188</u>	<u>0</u>	<u>300</u>

Perforations:  
Type perforation factory slot  
Size perforation 3/32 x 3"  
From 260 feet to 300 feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 50'  Neat Cement  
Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
From 50' feet to 300' feet

9. WATER LEVEL  
Static water level 224 feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature cold °F Quality good

Date started 2 12 1994  
Date completed 2 26 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>8</u>	<u>UK</u>	<u>11</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ed Miller Contractor  
Address P.O. Box 92 Smith  
Nevada 89430 Contractor  
Nevada contractor's license number issued by the State Contractor's Board 32166  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 7187  
Signed Ed Miller  
By driller performing actual drilling on site or contractor  
Date 2 26 94