

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 44061
 Permit No. _____
 Basin 4-59

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20862

1. OWNER Baker Hughes INTEQ ADDRESS AT WELL LOCATION RW-4
 MAILING ADDRESS P.O. Box 277 Milpark Drilling Fluids
Battle Mountain, NV 89820 Argenta, NV
 2. LOCATION SW 1/4 SW 1/4 Sec. 6 T. 32 N. S. R. 47 E. Lander County
 PERMIT NO. M/O 498-C Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown silt		0	10	10
Brown sandy silt		10	15	5
Brown silt	X	15	20	5
Brown clay & silt		20	25	5
Brown silty clay		25	32	7
Brown silty sand with gravel		32	36	4
Brown sand		36	40	4
Traffic box cover				
0 - 2 ft.				

8. WELL CONSTRUCTION
 Depth Drilled 40 Feet Depth Cased 40 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 40 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6" PVC		Sch. 40	0	8

Perforations:
 Type perforation Slotted 6" PVC
 Size perforation Sch. 40 20 slot
 From 8 feet to 40 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 8 ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No 10-20 Silica Sand
 From 8 feet to 40 feet

9. WATER LEVEL
 Static water level 14.6 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Elsing Drilling & Pump Co., Inc. Contractor
 Address P.O. Box 919 Contractor
Twin Falls, ID 83303-0919
 Nevada contractor's license number 0017177
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1479
 Signed Donald Elsing
 By driller performing actual drilling on site or contractor
 Date March 23, 1994

Date started 2-22, 1994
 Date completed 3-4, 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	