

OFFICE USE ONLY
 Log No. 44081
 Permit No. 6-88
 Basin 6-88

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23397

Consultant: CSA INC./GEORGE J. GEORGESON
 1. OWNER ACE CORPORATION/LOCKWOOD TRAILOR PARK
 MAILING ADDRESS 1000 Bible Way, Suite 16
Reno, NV 89502
 ADDRESS AT WELL LOCATION Near Fire Station, Lockwood, NV
 2. LOCATION NW 1/4 NW 1/4 Sec. 21 T 19 N N/S R. 21 E Storey County
 PERMIT NO. M/O - 757 MW#1 Lockwood Subdivision Name
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other TUBEX.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fill		0	2	2
Brown sand w/small to medium gravel, moist @ about 8 feet		2	10	8
Very moist		10	11	1
Color change brown to orange (dry) cuttings		11	13	2
Large gravel & rock (moist) cuttings		13	15	2
Consolidated rock		15	23	8
Med soft rock		23	25	2
Check for water after 15 feet. Yes				

8. WELL CONSTRUCTION
 Depth Drilled 25 Feet Depth Cascd 25 Feet
 HOLE DIAMETER (BIT SIZE)
 From 7 1/4 Inches To 0 Feet 25 Feet
 Inches.....Fcct.....Feet
 Inches.....Feet.....Fcct.....Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		sch 40	0	25
2" PVC end cap				
2" PVC locking cap				

 Perforations:
 Type perforation factory sawed slot
 Size perforation .020 x 1 1/4 x 3 rows
 From 10 feet to 25 feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 From.....feet to.....feet
 Surface Seal: Yes No Seal Type: PER
 Depth of Seal 5 FEET Neat Cement Tellur
 Cement Grout FTX
 Concrete Grout FTX
 Placement Method: Pumped Poured
BENTONITE 3 FEET
 Gravel Packed: Yes No FROM WAYNE DRILLING
 From.....feet to.....feet MD. 445

9. WATER LEVEL
 Static water level 7.3 1/2 feet below land surface
 Artesian flow not known G.P.M. P.S.I.
 Water temperature N/A °F Quality N/A

Date started 2-22-94, 19.....
 Date completed 2-22-94, 19.....

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
89510 RENO, NV 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
 Signed Wayne Drilling
 By driller performing actual drilling on site or contractor
 Date March 10, 1994