

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26489

1. OWNER DENNIS BADEN ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 7524 15495 (Pyramid Hwy.) SR 445
Reno, NV 89510 Reno, NV 89510
 2. LOCATION SE 1/4 SW 1/4 Sec 12 T 22N N/S R 20 E F. Washoe County
 PERMIT NO. 56164 076-252-10 Palomino Valley Unit 5 12-2-0-6
Issued by Water Resources Parcel No. Subdivision Name Par. 2

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test Municipal/Industrial Monitor Stock Air Other _____
 5. WELL TYPE Cable Rotary RVC

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy soil		0	3	3
Rock & clay		3	4	1
Brown clay		4	34	30
Gray clay		34	58	24
Light gray clay		58	69	11
Gray clay		69	89	20
Gray clay, soft		89	121	32
Lighth gray clay		121	165	44
Gray XXXX clay, brittle X?		165	176	11
Brittle clay		176	181	5
Gray clay, soft		181	209	28
Gray clay very soft		209	249	40
Gray brittle clay		249	305	56
Soft zone		305	308	3
Gray clay		308	327	19
Gray sandy clay, soft X		327	331	4
Med. sandy clay, light gray		331	386	55
Soft zone		386	390	4
Med. hard sandy clay		390	400	10

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 401 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 50 Feet
8 5/8 Inches 50 Feet 400 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Fect)	To (Feet)
6 5/8		.188	0	400

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 160 feet to 180 feet
 From 240 feet to 260 feet
 From 320 feet to 340 feet
 From 380 feet to 400 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal: 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 400 feet

NOTE: Several tests were made to try to determine well yield before installing casing.

7. WELL TEST DATA

Date started 3-22-94, 19____
 Date completed 3-25-94, 19____

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.		

9. WATER LEVEL
 Static water level 44 feet below land surface
 Artesian flow _____ G.P.M. 5.5 P.S.I.
 Water temperature cold °F Quality May have iron?

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. BOX 12370 Contractor
RENO, NV 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the 908
 Division of Water Resources, the on-site driller.
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date March 31, 1994