

OFFICE USE ONLY
 Log No. 44089
 Permit No. _____
 Basin. 6-35

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24408

1. OWNER JIM RODRIGUES ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1190 Glen Molly Crt. El Molino ct.
Sparks, NV 89434 302AB Sparks, NV 89436
 2. LOCATION NE 1/4 N 1/2 1/4 Sec. 3019 T. 21N N/S R. 21 E. Washoe County
 PERMIT NO. 076-380-27 Spanish Springs
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other Clean
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL CLEAN OUT & DEEPENING:				
Clean out to 169 ft. (wood, rocks, mice smell is bad).				
Steel in hole at 169 ft.				
Drill out steel, continue to drill.				
Lots of sand encountered.				
Bottom of casing at 175 feet.				
Yield approx. 3 GPM with air. 3-22-94				
DEEPENING:				
Brown sand, fine to medium.	X	175	200	25
Stabilize hole with 5"OD steel casing from 0 to 200 feet.				
Drill out the bottom for other WB strata.				
Encountered more steel at 203 feet, (appears to be broken tool - but not sure) Can not drill through.				
More sand coming in at bottom, cave in.				
Trip out of hole.				
Yield approx. 3 1/2 GPM with air. 3-24-94				

8. WELL CONSTRUCTION
 Depth Drilled 203 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
6 1/8 Inches 175 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	200

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 155 feet to 195 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped Poured
 Gravel Pack: Yes No
 From 100 feet to 200 feet

9. WATER LEVEL
 Static water level 135 feet below land surface
 Artesian flow _____ G.P.M. 3 1/2 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC. Contractor
 Address P.O. Box 12370 Contractor
Reno, NV 89510
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 973
 Signed Edward J. [Signature]
 By driller performing actual drilling on site or contractor
 Date March 28, 1994

Date started 3-22-94, 19____
 Date completed 3-24-94, 19____

7. WELL TEST DATA

TEST METHOD	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)