WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44128
Permit No.
Basin 8-10

NOTICE OF INTENT NO.

1. OWNER Guard L.T.D.
MAILING ADDRESS 3130 Villa Mashella Cir. Reno, NV 89509-6602
ADDRESS AT WELL LOCATION 5900 Dayton Ave. Silver Springs, NV 89429
N39.386624 W119.321871 NAD27

2. LOCATION NW ¼ NW ¼ Sec. 32 T. 18 N/S R. 24 E. Lyon County
PERMIT NO. Issued by Water Resources
18-451-15 Parcel No.
Hollywood Hills Sub#1 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
surface hard packed cobble stones & boulder		0	120	120
brown clay + some gravel		120	250	130
fractured volcane rock		250	295	45
hard fractured volcane rock	X	295	340	45
hard volcane rock		340	345	5

Deepened under NAC 534.42

Date started 3-6, 1994
Date completed 3-20, 1994

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8	40	2 hrs.

8. WELL CONSTRUCTION
Depth Drilled 345 Feet Depth Cased 345 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10 5/8	+0	345

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	.	.188	+1	345

Perforations:
Type perforation Mill
Size perforation 1/8 x 3
From 305 feet to 345 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 ft
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 345 feet

9. WATER LEVEL
Static water level 295 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good with iron taste

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ACE Drilling & Dev. Contractor
Address P.O. Box 668 Contractor
Silver Springs, NV 89429
Nevada contractor's license number issued by the State Contractor's Board 14299
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
Signed By driller performing actual drilling on site or contractor
Date 3/31/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627