WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 441
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 22929

1. OWNER Tony Stanfield
MAILING ADDRESS 592 Sutro Springs Rd. Dayton, Nevada 89403
ADDRESS AT WELL LOCATION 592 Sutro Springs Rd. Dayton, Nevada 89403

2. LOCATION NE ¼ NE ¼ Sec. 30 T. 17 N/S R 22 E Storey County
PERMIT NO. N/A (Issued by Water Resources) 03-285-06 (Parcel No.) Mark Twain (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 6 | 6 |
| Tan Clay with Some Gravel | | 6 | 54 | 48 |
| Brown Clay with Some Boulders | | 54 | 122 | 68 |
| Gravels and Boulders | | 122 | 163 | 41 |
| Brown Clay with Some Gravels | | 163 | 180 | 17 |
| Gravels and Boulders | | 180 | 240 | 60 |

'94 APR -8 P 1:15
STATE ENGINEER

Date started 3-15, 1994
Date completed 3-19, 1994

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| Developed For about 2 Hours | | |
| produced about 40 Gallons | | |
| A min. | | |

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 180 Feet |
| 6 1/4 Inches | 180 Feet | 240 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.00 | 3/16 | +1 | 180 |
| 5" | 11.00 | 3/16 | 180 | 240 |

Perforations:
Type perforation Factory Cut
Size perforation 3/16 x 2 x 5 Rows
From 160 feet to 180 feet
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 180 feet

9. WATER LEVEL
Static water level 140 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address PO Box 599 Silver Springs NV 89429 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1871
Signed [signature] By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627