REPORT NO. 94-16

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

4412

$-10-

NOTICE OF INTENT NO. 25804

1. OWNER: Tower Investments Inc.

ADDRESS OF WELL: Hwy 395 South

Owner's Address: P.O. Box 1788 Carson City, NV 89702

Douglas County

[X] Air [ ] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Reddish-brn clay, grn, yellow, wht, & orange volcanic gravel		0	15	15
Yellow clay wht, grn, tan, yellow D.G.		15		
sands		15	40	25
Reddish-brn clay, grn, yellow, orange,		40		
wht & brn volcanic gravels		40	67	27
Tan clay, yellow, wht, brn & tan D.G.		67		
sands & gravels	155	67	200	133

'94 FEB 28 P1:12

STATE ENGINEER'S OFFICE

Notes:

Date Started 2/16/94 Date Completed 2/17/94

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

GPM	DRAWDOWN	TIME (HRS)
154		2.5

8. WELL CONSTRUCTION

Depth Drilled: 200 Depth Cased: 200

HOLE DIAMETER (BIT SIZE)

10 5/8 Inches 0 Feet 55 Feet
8 1/2 Inches 55 Feet 200 Feet
Inches Feet Feet

CASING SCHEDULE

SIZE O.D.	WEIGHT/FT	WALL THICKNESS	FROM	TO
6 5/8	12.92	.188	+1.5	200

PERFORATIONS

Type Perforation: factory Size Perforation: 3/32 x 3

From 180 Feet to 180 Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No

Seal Depth: 51

PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

GRAVEL PACKED: [X] Yes [ ] No

From 51 Feet to 200 Feet

9. WATER LEVEL

Static Water Level: 70 Feet Below Land Surface

Artesian Flow: GPM PSI

Water Temperature: F Quality:

10. DRILLER'S CERTIFICATION

Name: AQUA DRILLING & WELL SERVICE INC.

Address: 826 SPICE ISLANDS DR. STE. 1
SPARKS, NV 89431

NV. CONTRACTOR'S LIC. NO. 15231 DRILLER'S LIC. NO. ON SITE 1511

Signed: Roger Mitchell

Dated 2/21/94