WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
# DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT
**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 44116
Permit No.
Basin 105

NOTICE OF INTENT NO. 24480

1. OWNER Phil Angst
MAILING ADDRESS 1474 Sanchez Rd. Gardnerville NV 89410
ADDRESS AT WELL LOCATION 1474 Sanchez Rd Gardnerville NV. 89410

2. LOCATION SE ¼ SE ¼ Sec. 25 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-540-19 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Overburden | | 0 | 3 | 3 |
| Large Gravels | | 3 | 28 | 25 |
| Soft DG Sands | | 28 | 39 | 11 |
| Brown Dry Clay | | 39 | 75 | 36 |
| Small Gravels w/ Clay Seems | | 75 | 83 | 8 |
| Gummy Solid Clay Brown. | | 83 | 105 | 22 |
| Small Gravels w/ obsidian Sands | XXX | 105 | 160 | 55 |

Date started 4-6, 1994
Date completed 4-8, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 407 | 25 | 3½ HRS |

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 10¾ | 0 | 160 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 16 5/8 | 13.03 | .188 | 0 | 160 |
| | | | | |
| | | | | |

Perforations:
Type perforation Mill Slot
Size perforation 3X 3/32
From 130 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 100
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 100 feet to 160 feet

9. WATER LEVEL
Static water level 30 feet below land surface
Artesian flow G.P.M. 407 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor)
Address (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack (By driller performing actual drilling on site or contractor)
Date 4-8-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627