WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 4477
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 24477

1. OWNER Egleland Construction
MAILING ADDRESS 1307 Yellow Jacket Grdnvl, NV 89423
ADDRESS AT WELL LOCATION 3533 Mt Blanca Drive Carson City 89706

2. LOCATION SE ¼ NW ¼ Sec. 11 T. 14 N S R. 19 E. Douglas County
PERMIT NO. Issued by Water Resources | 15-0-80-10 Parcel No. | Jacks Valley Ranches Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Sands		0	6	6
Rusty Orange DG Sands		6	18	12
Broken DG Sands		18	63	45
Course DG Sands Rusty		63	94	31
Hard Granite White & Black		94	150	56
Broken DG Gravels Rusty Sands	XXX	150	180	30

Date started 3-10, 1994
Date completed 3-12, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	45	3 HRS

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11¼ Inches	0 Feet	180 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	180

Perforations:
Type perforation Mill Slot
Size perforation 3 x 3/32
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55 feet to 180 feet

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & M PU... 5551 Hwy. 50 East ...rson City, Nev... ...-0459
Contractor
Address
Contractor

Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
Signed Michael L Hack
By driller performing actual drilling on site or contractor
Date 3-13-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627