

OFFICE USE ONLY  
 Log No. 44119  
 Permit No. 9-107  
 Basin 9-107

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2-57460

1. OWNER CHARLES FRAM ADDRESS AT WELL LOCATION 460 UPPER COLONY RD WELLS NV 89444  
 MAILING ADDRESS 5 PINON DRIVE WELLS NV 89444  
 2. LOCATION S.W. 1/4 S.W. 1/4 Sec. 10 T. 11 N/S R. 23 E LYON County  
 PERMIT NO. 1019302 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DH		0		20
DH		20		40
DH Bin clay		40		60
Brown clay		60		80
DG Clay		80		100
DG - Clay		100		120
DH		120		140
D.H.		140		160
gravel		160		180
gravel	✓	180		200
Bin clay		200		220
gravel	✓	220		240
gravel	✓	240		

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 240 Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		188	0	240

 Perforations:  
 Type perforation FACTORY SLOT  
 Size perforation 3/32 X 3  
 From 200 feet to 240 feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100'  Neat Cement  
 Placement Method:  Pumped  Poured  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 100 feet to 240 feet  
 9. WATER LEVEL  
 Static water level 100 feet below land surface  
 Artesian flow G.P.M. 25 + P.S.I.  
 Water temperature Cold °F Quality 9.000

Date started 3/5/94, 19\_\_\_\_  
 Date completed 3/8/94, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
		<u>3 HOURS</u>
		<u>25 9AM. +</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Ed Miller Contractor  
 Address P.O. Box 92 Smith NV 89430 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 32166  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 7187  
 Signed Ed Miller  
 By driller performing actual drilling on site or contractor  
 Date 3/8/94