

OFFICE USE ONLY
 Log No. 47121
 Permit No. 57854
 Basin. 107

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24479

1. OWNER Fred Alpars ADDRESS AT WELL LOCATION 192 Hudson Aurora Rd
 MAILING ADDRESS 4827 E. Sutor Terrace Smith Valley NV. 89430
Carson City NV. 89701
 2. LOCATION NE 1/4 NW 1/4 Sec. 34 T 11 S R. 24 E Lyon County
 PERMIT NO. 57854 Parcel No. 10-481-14 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	3	3
Small Gravels		3	27	24
Brown Sandy Clay		27	73	46
Gummy Brown Clay		73	94	21
Small Gravels		94	100	6
Hard Boulder				
Sandy Clays w/ small Imbedded Gravels		100	175	75
soft DG Sands		175	190	15
Small obsidian Gravels XX		190	220	30
Hard Broken obsidian XX Gravels		220	250	30

8. WELL CONSTRUCTION
 Depth Drilled 250 Feet Depth Cased 250 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 3/4 Inches 0 Feet 250 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>250</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 3x78
 From 110 feet to 250 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100'
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 100 feet to 250' feet

9. WATER LEVEL
 Static water level 50 feet below land surface
 Artesian flow _____ G.P.M. 200 P.S.I.
 Water temperature Cold °F Quality Good

Date started 3-28, 1994
 Date completed 4-1, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>200</u>	<u>60</u>	<u>4 1/2 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP & SERVICE
 Address Carson City, Nevada
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael J. Hack
 By driller performing actual drilling on site or contractor
 Date 4-2-94