WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44131
Permit No.
Basin 162

NOTICE OF INTENT NO. 12712

1. OWNER Odis C. Ostrander
MAILING ADDRESS
ADDRESS AT WELL LOCATION 450 E. Harris Farm Rd.

2. LOCATION SE ¼ SW ¼ Sec. 15 T. 19-S N/S R. 53 E. Nye County
PERMIT NO. (Issued by Water Resources) 29-292-15 (Parcel No.) Country Place II Unit 3 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy loam		0	7	7
Gravel		7	13	6
Sandy loam/gravel		13	52	39
Brown clay		52	129	77
Gravel		129	134	5
Brown clay	X	134	166	32
Brown clay/gravel	X	166	187	21
Brown clay	X	187	200	13

RECEIVED
APR 19 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started March 31, 1994
Date completed March 31, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	¼

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	200 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	200

Perforations:
Type perforation Torch Cut
Size perforation ¼in. width 8in. long
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 106 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING (Contractor)
Address P.O. BOX 56 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 17563
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324
Signed (By driller performing actual drilling on site or contractor)
Date April 1, 1994

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627