



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12179

1. OWNER MR. Roach ADDRESS AT WELL LOCATION Lot 49 Shady Ln
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 NE 1/4 Sec 8 T 20S N/S R. 53 E NYC County _____
 PERMIT NO. 35-152-16 Parcel No. _____ CAL DEONS RANCHOS Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	6	6
caliche		6	9	3
clay		9	24	15
caliche		24	26	2
Clay		26	42	16
caliche		42	48	6
Clay		48	68	20
caliche	WB	68	73	5
Clay		73	89	16
caliche	WB	89	92	3
Clay		92	99	7
caliche	WB	99	103	4
Clay		103	122	19
caliche	WB	122	126	4
Clay		126	133	7
caliche	WB	133	135	2
clay		135	140	5

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/4</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Saw cut
 Size perforation 1/8 x 3
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED
 MAR 08 1994

Div. of Water Resources
 Branch Office - Las Vegas, NV
 Date started 1-24, 1994
 Date completed 1-27, 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 49 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump NV 89041
 Nevada contractor's license number 30886
 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Damm
 By driller performing actual drilling on site or contractor
 Date 2-19-94