


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



Log No. 44178
 Permit No.
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 13004

1. OWNER Bill Miller ADDRESS AT WELL LOCATION 4639 S Dieckman Ave
 MAILING ADDRESS

2. LOCATION NW 1/4 SW 1/4 Sec 1 T. 21S N/S R. 53 E Nye County
 PERMIT NO. 44-011-22 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	5	5
Caliche		5	7	2
Clay		7	25	18
Caliche		25	28	3
Clay		28	46	18
Caliche		46	50	4
Clay		50	63	13
Caliche	WB	63	66	3
Clay		66	83	17
Caliche	WB	83	86	3
Clay		86	102	16
Caliche	WB	102	105	3
Clay		105	127	22
Caliche	WB	127	130	3
Clay		130	136	6
Caliche	WB	136	140	4

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 140 Feet
 Inches Feet Feet Feet
 Inches Feet Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Fracture SAW cut
 Size perforation 1/8 x 3
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

RECEIVED

MAR 08 1994

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 2-24 1994
 Date completed 2-26 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HER 78 Box 80358 Contractor
Parsons NV 89041
 Nevada contractor's license number 30880
 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dunn
 By driller performing actual drilling on site or contractor
 Date 3-2-94