WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44193
Permit No.
Basin

NOTICE OF INTENT NO. 12754

1. OWNER Roger Charbonneau
MAILING ADDRESS c/o Roger's Mobile Sales, Inc.
Star Rte. 1001 Hwy. 160, Pahrump, NV 89041
ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SE ¼ Sec. 11 T 21 ~~N~~ S R 54 E Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
REd clay & boulders		0	60	60
Gray clay & sm. bldrs.		60	200	140
Gr. clay, sm bldrs, some limestone (hard formation)		200	320	120
Gravel		320	360	40

RECEIVED
MAR 14 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started February 10, 19 94
Date completed February 15, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 351 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	360 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	16.9	.188	+1	351

Perforations:
Type perforation Mill slots
Size perforation 1/8 x 2" slots
From 280 feet to 351 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 360 feet

9. WATER LEVEL
Static water level 245 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMPSON DRILLING CO., INC. (Contractor)
Address 4185 West Harmon (Contractor)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489
Signed Richard K. Thompson (By driller performing actual drilling on site or contractor)
Date February 24, 1994

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627