WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44203
Permit No.
Basin 163

NOTICE OF INTENT NO. 3906

1. OWNER Eunice & Blair Farrington
MAILING ADDRESS 4350 S. Arville
Las Vegas, NV.

ADDRESS AT WELL LOCATION Mt. Springs, NV.

2. LOCATION NW ¼ SW ¼ Sec. 20 T. 22S N/S R. 58 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silt & loose				
limestone		0	18	
fractured limestone		18	105	
running gravel		105	113	
limestone & clay				
stringers		113	200	
First water @ 65'				

RECEIVED
MAR 24 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 2-15, 1994
Date completed 2-28, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased T.D. Feet

HOLE DIAMETER (BIT SIZE)

	From	To
9 7/8 Inches	0 Feet	105 Feet
7 7/8 Inches	105 Feet	T.D. Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	14.2	.188	+1	T.D.

Perforations:
Type perforation machine
Size perforation 1/8" X 2½"
From 124 feet to 139 feet
From 169 feet to 184 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to T.D. feet

9. WATER LEVEL
Static water level 44 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Briner Drilling Inc. (Contractor)
Address 555 N. Parkson Rd. (Contractor)
Henderson, NV. 89015
Nevada contractor's license number issued by the State Contractor's Board 6294A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 693
Signed M. D. Briner (By driller performing actual drilling on site or contractor)
Date Febuary 28, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

الدم