WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
# WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 44214
Permit No.
Basin 212

NOTICE OF INTENT NO. 12172

1. OWNER GLEN FANNIN
MAILING ADDRESS
ADDRESS AT WELL LOCATION JONES + BRENT

2. LOCATION NW ¼ NE ¼ Sec. 11 T. 19 N/S R. 60 E CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| SANDY CLAY. | | 0 | 10 | 10 |
| GRAVEL | | 10 | 20 | 10 |
| CLAY + CALICHE | | 20 | 120 | 100 |
| CALICHE W/ STRKS | 180 | 120 | 190 | 70 |
| BROWN LIME. | | | | |
| CLAY W/ STRKS | | 190 | 500 | 310 |
| CALICHE. | | | | |

RECEIVED
APR 13 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 4-4, 1994
Date completed 4-6, 1994

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12¼ Inches | | 0 Feet | 500 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | +1 | 500 |
| | | | | |
| | | | | |

Perforations:
Type perforation FACTORY SAW
Size perforation 18 x 2½
From 460 feet to 500 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 500 feet

9. WATER LEVEL
Static water level 150 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DESERT DRILLING (Contractor)
Address 6475 GARY AVE (Contractor)
LAS VEGAS, NV. 89139
Nevada contractor's license number issued by the State Contractor's Board 34274
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594
Signed Pyndall Couch (By driller performing actual drilling on site or contractor)
Date 4-11-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627