


WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
 Log No. 44240
 Permit No. _____
 Basin 212



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO12749

1. OWNER Michael J. Csizmadia ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1555 So. Rainbow Blvd. West side of Red Rock, South side of Quail
Las Vegas, NV 89102

2. LOCATION NW 1/4 NW 1/4 Sec 36 T 21 (S) R 60 E Clark County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & gravel		0	2	2
Caliche		2	18	16
Cem. sand & gravel		18	58	40
Sand, gravel & clay		58	120	62
Sand, gravel, clay some bldrs		120	160	40
Boulders		160	180	20
Sand, gravel & boulders		180	220	40
S & g, bldrs, some clay		220	240	20
Cem. sand & gravel		240	500	260

8. WELL CONSTRUCTION
 Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
12 Inches 0 Feet 500 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	+1	500

Perforations:
 Type perforation Mill slots
 Size perforation 1/8 x 2 1/2 8 ROWS
 From 418 feet to 500 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 500 feet


9. WATER LEVEL
 Static water level 340 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INC. Contractor
 Address 4185 West Harmon Contractor
Las Vegas, NV 89103

Nevada contractor's license number issued by the State Contractor's Board 4286A
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 856

Signed Richard R. Thompson
 By driller performing actual drilling on site or contractor
 Date January 20, 1994



Date started January 10, 1994
 Date completed January 19, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 FEB 09 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV